

AI in Energy: Optimizing Generation and Smart Grids

A.T. Svanovich^{1*}, E.V. Petrova²

¹ Department of Computer Science, National Research University, Almaty, Kazakhstan

² Institute for Digital Privacy & Security, Astana, Kazakhstan

Corresponding author: E.V. Petrova, email: e.petrova@idps.kz

Abstract

As variable renewable energy (VRE) rises, utilities must operate closer to limits without compromising reliability. This article presents a production-oriented framework for applying AI across the grid lifecycle. We detail (i) grid digital twins that fuse SCADA/PMU telemetry with physics-based models for contingency and “what-if” analysis; (ii) probabilistic load/VRE forecasting with calibrated uncertainty; (iii) orchestration of distributed energy resources (DER) and microgrids through multi-objective optimization and volt/VAR control; (iv) predictive maintenance that estimates remaining useful life (RUL) and reduces technical/non-technical losses; and (v) cyber-resilience for operational technology (OT) using anomaly detection and cyber-physical consequence modeling. A reference architecture couples time-series data platforms, feature stores, and MLOps with secure control loops to EMS/DMS. We propose a phased deployment plan, measurable KPIs, and a risk-mitigation matrix to help utilities and aggregators scale AI safely and transparently.

1. Context and objective

High VRE penetration increases uncertainty and reserve needs. AI reframes operations from reactive to anticipatory: learn patterns from high-frequency telemetry, forecast system states, optimize actions under network and market constraints, and execute with human oversight and auditability.

2. Grid digital twins

A digital twin is a continuously calibrated model of substations, feeders, and generation synchronized with SCADA/DMS and PMU streams. AI improves state estimation, topology reconciliation, parameter identification, and stability-margin inference. Twins enable fast N-1/N-k contingency studies and “what-if” scenarios (line outages, storage siting, maintenance shifts), support optimal power flow (OPF) decisions, and provide explainable recommendations to dispatchers.

3. Probabilistic forecasting of demand and VRE

Short- and medium-term forecasts (15-minute to 7-day) drive unit commitment and balancing costs. Gradient-boosted trees and sequence models (transformers) integrate weather ensembles, calendar effects, market signals, and behavioral features. Outputs should be **probabilistic** (quantiles, prediction intervals) with post-hoc calibration; for VRE, ensembles with meteorology error correction and site-level sensors reduce reserves and imbalance penalties.

4. DER and microgrid orchestration

Behind-the-meter PV, batteries, EVs, and heat pumps require local coordination. AI optimizes charge/discharge schedules, price- and frequency-responsive loads, feeder congestion relief, and volt/VAR support. At portfolio scale, virtual power plants (VPPs) monetize flexibility; in microgrids, multi-objective optimization balances cost, emissions, and reliability—even under islanding or degraded communications. Hosting-capacity assessment and constraint-aware dispatch prevent reverse-power issues and voltage excursions.

5. Predictive maintenance and loss reduction

Data- and model-driven diagnostics detect early faults (vibration spectra, partial discharges, infrared patterns, acoustic cues). RUL models schedule condition-based maintenance for transformers, breakers, and cables. Computer vision flags vegetation encroachment and insulator contamination. AI also localizes non-technical losses (pattern anomalies in AMI) and tunes VAR compensation to cut technical losses while respecting protection settings.


6. Cyber-resilience of energy systems

AI-assisted intrusion detection for OT correlates anomalous commands/telemetry with grid topology and consequence models, elevating explainable, high-impact alerts. Coupled with the digital twin, operators can “sandbox” responses, quantify load-shed trade-offs, and prevent cascading failures. Controls include least-privilege access, signed/timestamped commands, and tamper-evident logs integrated with SOC workflows.

7. Reference architecture

Layers and principles: observability, explainability for OT actions, graceful degradation under telemetry loss, least-privilege access, and auditable decision trails.

Data layer: SCADA/PMU/AMI/IoT + Weather APIs -> Time-Series Bus -> Data Lake



Model layer: Forecast (quantiles) | OPF/Optimization | Anomaly/IDS | RUL



Orchestration: MLOps (versioning, drift, A/B, lineage, approvals)



Control loop: EMS/DMS APIs -> Dispatcher HMI -> Secure Actuation (dual-control)

8. Phased deployment roadmap

Phase 1 — Discovery (4–6 weeks). Data inventory and quality baselines; target KPIs (MAPE/MAE, SAIDI/SAIFI, losses); OT threat model; governance artifacts (data catalog, model cards).

Phase 2 — Pilot (8–12 weeks). Probabilistic load/VRE forecasting and asset-health pilots on 1–2 feeders/substations; dashboards; human-in-the-loop approvals; twin-first simulation.

Phase 3 — Scale-out (12–20 weeks). DER/VPP orchestrator integrated with EMS/DMS; constraint-aware optimization; A/B and shadow modes; resilience playbooks.

Phase 4 — Operations (ongoing). Model refresh policy; drift and calibration monitoring; red-team exercises (faults/cyber); internal/external audits and periodic KPI reviews.

9. KPIs and value realization

- Forecast: MAE/MAPE (load and VRE), calibration error (PIT, coverage).
 - Operations: reserve and imbalance cost savings; SAIDI/SAIFI reduction; avoided forced outages; MTBF/MTTR.
 - Losses & power quality: technical/non-technical loss reduction; voltage violation rate; VAR cost.
 - Sustainability & scale: CO₂ intensity per MWh; % automated actions without escalation; time-to-restore after incidents.
- Value appears as CAPEX deferral (operating closer to limits with confidence) and OPEX reduction (condition-based maintenance, fewer penalties).

10. Risk and mitigation matrix

- **Data risk:** missing/skewed/unsynchronized streams → SLAs; data lineage; gap-filling with uncertainty flags; sensor redundancy.
- **Model risk:** black-box behavior, overfitting → XAI for OT actions; offline/online evals; canary tests; fallback heuristics.
- **Integration risk:** mis-execution in OT/Protection → dual-control approvals; twin-first simulation; rollback plans.
- **Security risk:** compromised channels → segmentation; least-privilege; signed commands; tamper-evident logging; SOC integration.
- **Market design risk:** misaligned incentives for flexibility → transparent procurement rules and verifiable settlement logic.

11. Conclusion

AI augments—not replaces—engineering rules by quantifying uncertainty and optimizing decisions under constraints. Utilities and aggregators that pair quality data, disciplined MLOps, and explainable, secure OT execution can scale AI from pilots to portfolio-level impact: tighter VRE balancing, lower losses, higher reliability, and faster recovery.

Keywords: *Artificial Intelligence; Power Systems; Digital Twins; Load Forecasting; DER; Microgrids; Cybersecurity*

Selected references (APA 7th)

- Electric Power Research Institute. (2022). *Artificial intelligence applications in electric power systems*. EPRI.
- International Energy Agency. (2023). *Digital demand-driven electricity systems*. IEA.
- IEEE Standards Association. (2017). *IEEE Std 2030.7-2017—Distribution resource energy management systems (DERMS) functional requirements*. IEEE.
- National Institute of Standards and Technology. (2015). *Guide to Industrial Control Systems (ICS) Security* (SP 800-82 Rev. 2). NIST.
- National Renewable Energy Laboratory. (2022). *Forecasting and modeling for grid-integrated renewables*. NREL.
- U.S. Department of Energy. (2024). *Grid modernization and energy storage program reports*. DOE.
- ENTSO-E. (2023). *Digital and interoperability strategy for the power system*. European Network of Transmission System Operators for Electricity.